

**Collins Elementary Sample Results**

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Collins Elementary WCCUSD	Fountain	DF in classroom 7	11/7/2019	EPA-200.8	Lead	2.0		0.1	1
Collins Elementary WCCUSD	Fountain	Right DF Outside classroom 16	11/7/2019	EPA-200.8	Lead	0.65	J	0.1	1
Collins Elementary WCCUSD	Tap	Right Tap in classroom 16	11/7/2019	EPA-200.8	Lead	1.8		0.1	1
Collins Elementary WCCUSD	Fountain	DF in main office	11/7/2019	EPA-200.8	Lead	8.3		0.1	1
Collins Elementary WCCUSD	Fountain	DF in multi purpose room	11/7/2019	EPA-200.8	Lead	7.1		0.1	1
Collins Elementary WCCUSD	Tap	Tap in kitchen in multi purpose room	11/7/2019	EPA-200.8	Lead	4.4		0.1	1
Collins Elementary WCCUSD	Tap	Tap in classroom 29	11/7/2019	EPA-200.8	Lead	2.9		0.1	1
Collins Elementary WCCUSD	Tap	Tap in speech room	11/7/2019	EPA-200.8	Lead	2.5		0.1	1
Collins Elementary WCCUSD	Fountain	Right DF Outside classroom 6	11/7/2019	EPA-200.8	Lead	0.16	J	0.1	1
Collins Elementary WCCUSD	Tap	Tap in classroom 23	11/7/2019	EPA-200.8	Lead	1.6		0.1	1
Collins Elementary WCCUSD	Tap	Tap in classroom 24	11/7/2019	EPA-200.8	Lead	2.1		0.1	1
Collins Elementary WCCUSD	Tap	Tap in classroom 25	11/7/2019	EPA-200.8	Lead	4.6		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 26	11/7/2019	EPA-200.8	Lead	0.82	J	0.1	1
Collins Elementary WCCUSD	Fountain	Left DF Outside classroom 19	11/7/2019	EPA-200.8	Lead	0.68	J	0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 17	11/7/2019	EPA-200.8	Lead	1.9		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 18	11/7/2019	EPA-200.8	Lead	0.83	J	0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 19	11/7/2019	EPA-200.8	Lead	3.3		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 20	11/7/2019	EPA-200.8	Lead	0.76	J	0.1	1
Collins Elementary WCCUSD	Tap	Tap in classroom 21	11/7/2019	EPA-200.8	Lead	11		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 22	11/7/2019	EPA-200.8	Lead	3.0		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 6	11/7/2019	EPA-200.8	Lead	1.9		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 5	11/7/2019	EPA-200.8	Lead	1.7		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 4	11/7/2019	EPA-200.8	Lead	1.6		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 3	11/7/2019	EPA-200.8	Lead	2.8		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 2	11/7/2019	EPA-200.8	Lead	4.6		0.1	1
Collins Elementary WCCUSD	Fountain	DF in classroom 1	11/7/2019	EPA-200.8	Lead	0.20	J	0.1	1
Collins Elementary WCCUSD	Fountain	Right DF Outside behind rm 16	11/7/2019	EPA-200.8	Lead	1.1		0.1	1

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit