

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Fairmont Elementary	Fountain	DF in classroom 6 near the door opposite the sink	10/22/2019	EPA-200.8	Lead	1.6		0.10	1.0
Fairmont Elementary	Fountain	DF opposite the door in classroom 7	10/22/2019	EPA-200.8	Lead	0.88	J	0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 5	10/22/2019	EPA-200.8	Lead	3.7		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 3	10/22/2019	EPA-200.8	Lead	2.5		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 4	10/22/2019	EPA-200.8	Lead	3.4		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 1	10/22/2019	EPA-200.8	Lead	3.2		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 2	10/22/2019	EPA-200.8	Lead	5.2		0.10	1.0
Fairmont Elementary	Fountain	Upper DF by girls rr	10/22/2019	EPA-200.8	Lead	ND		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 10	10/22/2019	EPA-200.8	Lead	3.1		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 9	10/22/2019	EPA-200.8	Lead	5.7		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 12	10/22/2019	EPA-200.8	Lead	2.2		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 11	10/22/2019	EPA-200.8	Lead	3.9		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 14	10/22/2019	EPA-200.8	Lead	19		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom 13	10/22/2019	EPA-200.8	Lead	15		0.10	1.0

Fairmont Elementary	Tap	Tap in classroom 15	10/22/2019	EPA-200.8	Lead	20		0.10	1.0
Fairmont Elementary	Fountain	Lower DF by exit by for classroom 15 and girls rr	10/22/2019	EPA-200.8	Lead	0.11	J	0.10	1.0
Fairmont Elementary	Fountain	DF in sink in P6	10/22/2019	EPA-200.8	Lead	1.6		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom P7	10/22/2019	EPA-200.8	Lead	0.81	J	0.10	1.0
Fairmont Elementary	Fountain	DF in classroom P8	10/22/2019	EPA-200.8	Lead	0.38	J	0.10	1.0
Fairmont Elementary	Tap	Tap in classroom P9	10/22/2019	EPA-200.8	Lead	1.5		0.10	1.0
Fairmont Elementary	Fountain	DF in classroom P10	10/22/2019	EPA-200.8	Lead	0.91	J	0.10	1.0
Fairmont Elementary	Fountain	DF in classroom P1	10/22/2019	EPA-200.8	Lead	0.52	J	0.10	1.0
Fairmont Elementary	Water Dispenser	Bottle filler in cafeteria	10/22/2019	EPA-200.8	Lead	4.1		0.10	1.0
Fairmont Elementary	Fountain	Outside right DF next to classroom 6	10/22/2019	EPA-200.8	Lead	0.14	J	0.10	1.0
Fairmont Elementary	Tap	Tap in kitchen	10/22/2019	EPA-200.8	Lead	20		0.10	1.0
Fairmont Elementary	Fountain	Right DF outside room 18	10/22/2019	EPA-200.8	Lead	1.7		0.10	1.0
Fairmont Elementary	Tap	Tap in classroom 18	10/22/2019	EPA-200.8	Lead	1.7		0.10	1.0
Fairmont Elementary	Tap	Tap in classroom 17	10/22/2019	EPA-200.8	Lead	6.8		0.10	1.0