

Highland Elementary Expanded Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Highland Elementary	Tap	Tap in teachers lounge	10/31/2019	EPA-200.8	Lead	0.57	J	0.1	1
Highland Elementary	Fountain	DF in classroom 12	10/31/2019	EPA-200.8	Lead	16		0.1	1
Highland Elementary	Fountain	DF in classroom 13	10/31/2019	EPA-200.8	Lead	5.7		0.1	1
Highland Elementary	Fountain	DF in classroom 14	10/31/2019	EPA-200.8	Lead	6.3		0.1	1
Highland Elementary	Tap	Tap in classroom 15	10/31/2019	EPA-200.8	Lead	6.0		0.1	1
Highland Elementary	Tap	Tap in classroom 18	10/31/2019	EPA-200.8	Lead	16		0.1	1
Highland Elementary	Tap	Tap in classroom 16	10/31/2019	EPA-200.8	Lead	5.1		0.1	1
Highland Elementary	Tap	Tap in classroom 19	10/31/2019	EPA-200.8	Lead	3.4		0.1	1
Highland Elementary	Tap	Tap in classroom 17	10/31/2019	EPA-200.8	Lead	5.7		0.1	1
Highland Elementary	Tap	Tap in classroom 20	10/31/2019	EPA-200.8	Lead	8.9		0.1	1
Highland Elementary	Fountain	DF in classroom 21	10/31/2019	EPA-200.8	Lead	11		0.1	1
Highland Elementary	Fountain	DF in classroom 22	10/31/2019	EPA-200.8	Lead	17		0.1	1
Highland Elementary	Fountain	Left DF Outside classroom 7	10/31/2019	EPA-200.8	Lead	0.45	J	0.1	1
Highland Elementary	Fountain	Left DF outside classroom 11	10/31/2019	EPA-200.8	Lead	0.24	J	0.1	1
Highland Elementary	Fountain	Left DF outside classroom 15	10/31/2019	EPA-200.8	Lead	0.91	J	0.1	1
Highland Elementary	Tap	Tap in classroom 11	10/31/2019	EPA-200.8	Lead	1.3		0.1	1
Highland Elementary	Fountain	DF in classroom 7	10/31/2019	EPA-200.8	Lead	2.0		0.1	1
Highland Elementary	Fountain	DF in classroom 10	10/31/2019	EPA-200.8	Lead	2.5		0.1	1
Highland Elementary	Fountain	DF in classroom 6	10/31/2019	EPA-200.8	Lead	0.22	J	0.1	1
Highland Elementary	Tap	Tap in classroom 9	10/31/2019	EPA-200.8	Lead	74		0.1	1
Highland Elementary	Fountain	DF in classroom 5	10/31/2019	EPA-200.8	Lead	1.9		0.1	1
Highland Elementary	Tap	Tap in classroom 8	10/31/2019	EPA-200.8	Lead	4.1		0.1	1
Highland Elementary	Fountain	DF in classroom 4	10/31/2019	EPA-200.8	Lead	0.68	J	0.1	1
Highland Elementary	Fountain	DF in classroom 3	10/31/2019	EPA-200.8	Lead	0.51	J	0.1	1
Highland Elementary	Tap	Tap in classroom K2	10/31/2019	EPA-200.8	Lead	10		0.1	1
Highland Elementary	Tap	Tap in classroom K1	10/31/2019	EPA-200.8	Lead	1.8		0.1	1
Highland Elementary	Tap	Tap in kitchen in multi purpose room	10/31/2019	EPA-200.8	Lead	16		0.1	1

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit