

Peres Elementary Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Peres Elementary WCCUSD	Fountain	Lower fountain near bathrooms between learning c	12/13/2019	EPA-200.8	Lead	0.37	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 23	12/13/2019	EPA-200.8	Lead	0.62	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room K1	12/13/2019	EPA-200.8	Lead	0.11	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 2	12/13/2019	EPA-200.8	Lead	0.11	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 4	12/13/2019	EPA-200.8	Lead	0.25	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 7	12/13/2019	EPA-200.8	Lead	0.25	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 5	12/13/2019	EPA-200.8	Lead	0.28	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room K3	12/13/2019	EPA-200.8	Lead	0.28	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room K2	12/13/2019	EPA-200.8	Lead	0.27	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 8	12/13/2019	EPA-200.8	Lead	0.4	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 10	12/13/2019	EPA-200.8	Lead	0.2	J	0.1	1
Peres Elementary WCCUSD	Fountain	Upper DF by room 11	12/13/2019	EPA-200.8	Lead	ND		0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 16	12/13/2019	EPA-200.8	Lead	0.78	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 14	12/13/2019	EPA-200.8	Lead	0.7	J	0.1	1
Peres Elementary WCCUSD	Fountain	Upper by room K4	12/13/2019	EPA-200.8	Lead	0.22	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room K4	12/13/2019	EPA-200.8	Lead	0.88	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 17	12/13/2019	EPA-200.8	Lead	0.41	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 19	12/13/2019	EPA-200.8	Lead	0.14	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 20	12/13/2019	EPA-200.8	Lead	0.28	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in room 22	12/13/2019	EPA-200.8	Lead	0.19	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in preschool	12/13/2019	EPA-200.8	Lead	0.36	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in SPED	12/13/2019	EPA-200.8	Lead	0.49	J	0.1	1
Peres Elementary WCCUSD	Fountain	Fountain on right side of sink in second sped room	12/13/2019	EPA-200.8	Lead	0.29	J	0.1	1
Peres Elementary WCCUSD	Water Dispense	Water bottle filler right side in multipurpose room	12/13/2019	EPA-200.8	Lead	ND		0.1	1

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit

ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit