

Olinda Elementary Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Olinda Elementary WCCUSD	Tap	Tap in Side room in between main office and teach	11/22/2019	EPA-200.8	Lead	0.59	J	0.1	1
Olinda Elementary WCCUSD	Fountain	DF in TK room	11/22/2019	EPA-200.8	Lead	2.0		0.1	1
Olinda Elementary WCCUSD	Fountain	Left DF Outside TK room	11/22/2019	EPA-200.8	Lead	0.81	J	0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 1	11/22/2019	EPA-200.8	Lead	0.79	J	0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 5	11/22/2019	EPA-200.8	Lead	1.8		0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 2	11/22/2019	EPA-200.8	Lead	1.1		0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 6	11/22/2019	EPA-200.8	Lead	1.4		0.1	1
Olinda Elementary WCCUSD	Tap	Tap in classroom 3	11/22/2019	EPA-200.8	Lead	2.5		0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 7	11/22/2019	EPA-200.8	Lead	0.41	J	0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 4	11/22/2019	EPA-200.8	Lead	0.64	J	0.1	1
Olinda Elementary WCCUSD	Fountain	DF in classroom 8	11/22/2019	EPA-200.8	Lead	0.45	J	0.1	1
Olinda Elementary WCCUSD	Fountain	Left DF Outside boys rr	11/22/2019	EPA-200.8	Lead	0.29	J	0.1	1
Olinda Elementary WCCUSD	Fountain	Lower df outside girls rr	11/22/2019	EPA-200.8	Lead	ND		0.1	1
Olinda Elementary WCCUSD	Tap	Tap in kitchen in multi purpose room	11/22/2019	EPA-200.8	Lead	7.0		0.1	1

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit