

**Richmond High School Sample Results**

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Richmond High School WCCUSD	Fountain	DF in classroom 341	11/14/2019	EPA-200.8	Lead	22		0.1	1
Richmond High School WCCUSD	Fountain	DF in room 360	11/14/2019	EPA-200.8	Lead	3.2		0.1	1
Richmond High School WCCUSD	Fountain	DF in library next to textbook room	11/14/2019	EPA-200.8	Lead	19		0.1	1
Richmond High School WCCUSD	Tap	Tap in dish washing pit next to kitchen	11/14/2019	EPA-200.8	Lead	0.72	J	0.1	1
Richmond High School WCCUSD	Tap	Tap in side room off kitchen	11/14/2019	EPA-200.8	Lead	13		0.1	1
Richmond High School WCCUSD	Tap	Tap in kitchen next to office	11/14/2019	EPA-200.8	Lead	1.4		0.1	1
Richmond High School WCCUSD	Fountain	DF in classroom 508	11/14/2019	EPA-200.8	Lead	37		0.1	1
Richmond High School WCCUSD	Tap	Right tap in classroom 611	11/14/2019	EPA-200.8	Lead	2.8		0.1	1
Richmond High School WCCUSD	Tap	Left Tap in classroom 609 (to the right from entrance)	11/14/2019	EPA-200.8	Lead	11		0.1	1
Richmond High School WCCUSD	Tap	Middle right side tap in room 636 (facing Chem lab)	11/14/2019	EPA-200.8	Lead	4.2		0.1	1
Richmond High School WCCUSD	Water Dispense	Water bottle dispenser next to admin entrance	11/14/2019	EPA-200.8	Lead	1.9		0.1	1
Richmond High School WCCUSD	Tap	Tap in room 209	11/14/2019	EPA-200.8	Lead	4.9		0.1	1
Richmond High School WCCUSD	Fountain	Left DF in girls locker room by exit to small gym (75)	11/14/2019	EPA-200.8	Lead	2.1		0.1	1
Richmond High School WCCUSD	Fountain	Lower df next to concessions at football field	11/14/2019	EPA-200.8	Lead	0.52	J	0.1	1
Richmond High School WCCUSD	Tap	Tap in snack bar over triple sink	11/14/2019	EPA-200.8	Lead	0.86	J	0.1	1
Richmond High School WCCUSD	Fountain	Lower DF in team room	11/14/2019	EPA-200.8	Lead	1.4		0.1	1
Richmond High School WCCUSD	Tap	Tap in classroom 556	11/14/2019	EPA-200.8	Lead	2.0		0.1	1
Richmond High School WCCUSD	Tap	Tap in classroom 555	11/14/2019	EPA-200.8	Lead	0.88	J	0.1	1
Richmond High School WCCUSD	Fountain	Fountain on left side of sink in back corner of 375	11/14/2019	EPA-200.8	Lead	3.7		0.1	1
Richmond High School WCCUSD	Fountain	Water bottle dispenser and fountain combo on the	11/14/2019	EPA-200.8	Lead	ND		0.1	1
Richmond High School WCCUSD	Tap	3 basin wash sink in cafeteria kitchen, left side	11/14/2019	EPA-200.8	Lead	27		0.1	1
Richmond High School WCCUSD	Tap	Room 506 sink	11/14/2019	EPA-200.8	Lead	4.0		0.1	1
Richmond High School WCCUSD	Fountain	Water fountain on left side of sink in room 607	11/14/2019	EPA-200.8	Lead	5.2		0.1	1
Richmond High School WCCUSD	Tap	Chem lab sink at front of classroom area room 634	11/14/2019	EPA-200.8	Lead	4.2		0.1	1
Richmond High School WCCUSD	Tap	Left side tap in sink inside teachers lounge in office	11/14/2019	EPA-200.8	Lead	2.0		0.1	1
Richmond High School WCCUSD	Fountain	Lower fountain in gym area on left side when you walk	11/14/2019	EPA-200.8	Lead	7.0		0.1	1
Richmond High School WCCUSD	Fountain	Lower fountain in boys locker room near office area	11/14/2019	EPA-200.8	Lead	7.2		0.1	1

Richmond High School WCCUSD	Fountain	Lower fountain in soccer training room through door	11/14/2019	EPA-200.8	Lead	1.5		0.1	1
Richmond High School WCCUSD	Tap	Sink in back of portable room 557	11/14/2019	EPA-200.8	Lead	0.91	J	0.1	1

<b>Analytical Notes And Definitions:</b>
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit
* = resample after corrective action