

Stege Elementary Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Stege Elementary	Tap	Tap in faculty lounge across from room 7	10/29/2019	EPA-200.8	Lead	2.0		0.1	1
Stege Elementary	Tap	Tap next to rr in the office	10/29/2019	EPA-200.8	Lead	0.31	J	0.1	1
Stege Elementary	Tap	Tap in classroom 15	10/29/2019	EPA-200.8	Lead	1.1		0.1	1
Stege Elementary	Tap	Tap in classroom 18	10/29/2019	EPA-200.8	Lead	ND		0.1	1
Stege Elementary	Tap	Tap in classroom 17	10/29/2019	EPA-200.8	Lead	1.1		0.1	1
Stege Elementary	Tap	Tap in classroom 20	10/29/2019	EPA-200.8	Lead	0.44	J	0.1	1
Stege Elementary	Tap	Tap in kitchen next to multi purpose room	10/29/2019	EPA-200.8	Lead	2.3		0.1	1
Stege Elementary	Fountain	Lower df next to girls rr outside across from faculty	10/29/2019	EPA-200.8	Lead	ND		0.1	1
Stege Elementary	Fountain	Upper DF next to media room	10/29/2019	EPA-200.8	Lead	0.23	J	0.1	1
Stege Elementary	Fountain	Lower DF Outside rr next to portables	10/29/2019	EPA-200.8	Lead	0.83	J	0.1	1

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit