

Tara Hills Elementary Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Tara Hills Elementary	Tap	Tap in teachers lounge	12/4/2019	EPA-200.8	Lead	0.35	J	0.1	1
Tara Hills Elementary	Tap	Tap in nurses office	12/4/2019	EPA-200.8	Lead	0.25	J	0.1	1
Tara Hills Elementary	Fountain	Upper DF across from admin	12/4/2019	EPA-200.8	Lead	0.24	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P2	12/4/2019	EPA-200.8	Lead	0.42	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P1	12/4/2019	EPA-200.8	Lead	0.39	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P4	12/4/2019	EPA-200.8	Lead	ND		0.1	1
Tara Hills Elementary	Fountain	DF in classroom P3	12/4/2019	EPA-200.8	Lead	0.15	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P6	12/4/2019	EPA-200.8	Lead	0.12	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P5	12/4/2019	EPA-200.8	Lead	0.33	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom P8	12/4/2019	EPA-200.8	Lead	ND		0.1	1
Tara Hills Elementary	Fountain	DF in classroom P7	12/4/2019	EPA-200.8	Lead	0.36	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom K2	12/4/2019	EPA-200.8	Lead	0.17	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom K1	12/4/2019	EPA-200.8	Lead	0.23	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom K3	12/4/2019	EPA-200.8	Lead	2.5		0.1	1
Tara Hills Elementary	Fountain	DF in classroom K4	12/4/2019	EPA-200.8	Lead	0.11	J	0.1	1
Tara Hills Elementary	Tap	Tap in occupational therapy room	12/4/2019	EPA-200.8	Lead	0.53	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom 13	12/4/2019	EPA-200.8	Lead	0.81	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom I4	12/4/2019	EPA-200.8	Lead	0.38	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom I5	12/4/2019	EPA-200.8	Lead	0.14	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom I7	12/4/2019	EPA-200.8	Lead	ND		0.1	1
Tara Hills Elementary	Fountain	DF in classroom I6	12/4/2019	EPA-200.8	Lead	0.33	J	0.1	1
Tara Hills Elementary	Tap	Tap in community kitchen	12/4/2019	EPA-200.8	Lead	0.32	J	0.1	1
Tara Hills Elementary	Fountain	Upper DF in multi purpose room	12/4/2019	EPA-200.8	Lead	0.14	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom N1	12/4/2019	EPA-200.8	Lead	0.2	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom N2	12/4/2019	EPA-200.8	Lead	0.56	J	0.1	1
Tara Hills Elementary	Tap	Tap in classroom N3	12/4/2019	EPA-200.8	Lead	0.39	J	0.1	1
Tara Hills Elementary	Fountain	DF in classroom N5	12/4/2019	EPA-200.8	Lead	0.44	J	0.1	1
Tara Hills Elementary	Fountain	Upper DF behind classroom 17, outside	12/4/2019	EPA-200.8	Lead	0.22	J	0.1	1

Tara Hills Elementary Sample Results

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
-------------	---------------	----------------------	--------------	--------	-----------	---------------	-----------	-----	-----

Analytical Notes And Definitions:
J = Estimated Value (CLP Flag)
MDL = Method Detection Limit
ND = Not Detected above the method detection limit
PQL = Practical Quantitation Limit