

West Contra Costa USD Lead Sampling Results

School Name	School ID	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
Madera Elementary	357	Fountain	Left DF by playground and to the right of rm 7	3/6/2018	EPA-200.8	Lead	ND		0.1	1
Madera Elementary	357	Fountain	Lower DF by multipurpose rm and main school entrance	3/6/2018	EPA-200.8	Lead	0.34	J	0.1	1
Madera Elementary	357	Fountain	Lower DF across from conference A114	3/6/2018	EPA-200.8	Lead	0.23	J	0.1	1
Madera Elementary	357	Fountain	Df in sink in rm 16	3/6/2018	EPA-200.8	Lead	0.32	J	0.1	1
Madera Elementary	357	Fountain	Right DF downstairs by B102	3/6/2018	EPA-200.8	Lead	0.18	J	0.1	1
Madera Elementary	357	Fountain	Lower DF by rm A120	3/6/2018	EPA-200.8	Lead	0.26	J	0.1	1
Madera Elementary	357	Fountain	Df in rm 13 sink	3/6/2018	EPA-200.8	Lead	0.38	J	0.1	1
Madera Elementary	357	Fountain	Left df outside to the left of the multipurpose rm	3/6/2018	EPA-200.8	Lead	ND		0.1	1
Fairmont Elementary	337	Tap	Tap in teachers lounge	3/6/2018	EPA-200.8	Lead	1.5		0.1	1
Fairmont Elementary	337	Fountain	Middle DF by the rm 6	3/6/2018	EPA-200.8	Lead	0.26	J	0.1	1
Fairmont Elementary	337	Fountain	Lower DF by girls rr	3/6/2018	EPA-200.8	Lead	ND		0.1	1
Fairmont Elementary	337	Fountain	DF in sink in rm 9	3/6/2018	EPA-200.8	Lead	0.95	J	0.1	1
Fairmont Elementary	337	Fountain	Left DF outside rm 18	3/6/2018	EPA-200.8	Lead	1.5		0.1	1
Fairmont Elementary	337	Fountain	Df in rm 18 sink	3/6/2018	EPA-200.8	Lead	1.3		0.1	1
Fairmont Elementary	337	Fountain	Left df on corner by rm 14 across from P3	3/6/2018	EPA-200.8	Lead	0.23	J	0.1	1
Fairmont Elementary	337	Fountain	Df in rm 15 sink	3/6/2018	EPA-200.8	Lead	1.1		0.1	1
Kensington Elementary	351	Fountain	Lower DF by offiCe by O.T. room	3/6/2018	EPA-200.8	Lead	0.2	J	0.1	1
Kensington Elementary	351	Fountain	Lower DF in multipurpose rm	3/6/2018	EPA-200.8	Lead	0.17	J	0.1	1
Kensington Elementary	351	Fountain	Lower DF to the left of rm 19 and across from rm 21	3/6/2018	EPA-200.8	Lead	ND		0.1	1
Kensington Elementary	351	Fountain	Lower DF by library entrance outside to the left of rm 20	3/6/2018	EPA-200.8	Lead	0.14	J	0.1	1
Kensington Elementary	351	Fountain	Lower DF to the left of rm 15	3/6/2018	EPA-200.8	Lead	ND		0.1	1
Kensington Elementary	351	Fountain	Df in sink in kindergarten rm 2	3/6/2018	EPA-200.8	Lead	0.31	J	0.1	1
Kensington Elementary	351	Fountain	Lower df by portable 1 across from kindergarten rm 3	3/6/2018	EPA-200.8	Lead	0.2	J	0.1	1
Kensington Elementary	351	Tap	Tap in teachers lounge	3/6/2018	EPA-200.8	Lead	0.14	J	0.1	1

Analytical Notes And Definitions:

J = Estimated Value (CLP Flag)
 MDL = Method Detection Limit
 ND = Not Detected above the method detection limit
 PQL = Practical Quantitation Limit
 C-04 = Result confirmed by re-analysis