

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/L)	Qualifier	MDL	PQL
West County Mandarin	Fountain	DF in classroom 9	10/24/2019	EPA-200.8	Lead	13		0.10	1.0
West County Mandarin	Tap	Tap in classroom 8	10/24/2019	EPA-200.8	Lead	2.4		0.10	1.0
West County Mandarin	Fountain	Lower DF Outside classroom 7 entrance	10/24/2019	EPA-200.8	Lead	0.43	J	0.10	1.0
West County Mandarin	Fountain	DF in classroom 6	10/24/2019	EPA-200.8	Lead	11		0.10	1.0
West County Mandarin	Fountain	DF in classroom 4	10/24/2019	EPA-200.8	Lead	5.2		0.10	1.0
West County Mandarin	Tap	Tap in back corner room next to main office	10/24/2019	EPA-200.8	Lead	0.35	J	0.10	1.0
West County Mandarin	Fountain	DF in multi purpose room	10/24/2019	EPA-200.8	Lead	0.96	J	0.10	1.0
West County Mandarin	Tap	Tap in classroom 11	10/24/2019	EPA-200.8	Lead	0.13	J	0.10	1.0
West County Mandarin	Tap	Tap in classroom 12	10/24/2019	EPA-200.8	Lead	0.16	J	0.10	1.0